

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1/2025

Dated:

It is certified that an inspection team headed by Mukesh Kumar (AE)

(Name of Officers with designation) from Uttarakhand Jal Sanstha <sup>Uttam Singh Nagar</sup> PHED

inspected the Maregay Public School Sitarganj Road Pachpeda Nand <sup>U.S</sup>

(Name & Address of the school) on 16-06-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 36/UJ.S/DCWQ.T.M/2025-20 dated 16-06-2025

of D.C.W.Q.T.M.L UJ.S (PHED Lab) certified that

the Rudrapur Uttam Singh Nagar (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till .....

Signature with Seal: सहायक अभियन्ता (मु०)

Name: उत्तराखण्ड जल संस्थान

Designation: उत्तम सिंह नगर

Name & Address of the Office / Department: .....

To Maregay Public School Sitarganj

Road Pachpeda Nandmatra U.S Nagar

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, Rudrapur U.S. Nagar  
E-mail: [eeudmuj@gmail.com](mailto:eeudmuj@gmail.com)

Test Report ID: 36/UJS/DLWQTML/2025-26

**WATER QUALITY TEST REPORT**


Name and Address of Organization/ Customer	Nosegay Public School, Sitarganj Road, Pachpeda, Nanaknatta (U.S. Nagar)		
Type of Source (Drinking Water/ Ground Water/ Sub-Surface Water)	Sample Description: Drinking Water	One water Sample Collect from School campus Ro	
Reference Sample Identification:	DLWQTML/UJS/NPS-01	Date of Start of Analysis: 13.06.2025	
		Date of End of Analysis : 16.06.2025	
Date of Sample Received: 13.06.2025, 11:45AM	Sample Collected by:	Customer	

S.No.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)
1	Colour	Less than 1	5	15
2	Odour	Unobjectionable	Unobjectionable	Unobjectionable
3	Taste	Agreeable	Agreeable	Agreeable
4	Total Dissolved Solids (TDS), mg/l max	40	500	2000
5	pH at 25°C	7.14	6.5 to 8.5	No Relaxation
6	Turbidity, NTU max	0.25	1	5
7	Chloride, Mg/l max	3.99	250	1000
8	Total Alkalinity as CaCO <sub>3</sub> mg/l max	28	200	600
9	Total Hardness as CaCO <sub>3</sub> mg/l max	24	200	600
10	Calcium as Ca mg/l max	8.0	75	200
11	Magnesium as Mg mg/l max	0.97	30	100
<b>Microbiological Test Parameters</b>				
12	E.Coli MPN /100ml	Absent	Absent	Absent
13	Total Colliform/100ml	Absent	Absent	Absent

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

  
Chemist

-End of Report-

  
Lab Incharge/Technical Manager  
Technical Manager  
District Water Quality Testing  
Monitoring Laboratory  
Uttarakhand Jal Sansthan, U.S. Nagar